

**2019 DPW and Municipal Office
Security Camera and Proximity Card Door System Bid
Bid No. RFP-2019-DPW-19**

ADDENDUM #1

Based on questions that were asked in the mandatory pre-bid meeting today at 9:00AM, the following responses are as follows:

- ExaqVision will be installed by Hi-Tech on the server, but the company awarded the bid will program all cameras and doors that are installed.
- All CAT6 line that is installed must be certified and Fluke tested
- Provide CAD drawings of all lines that are run for this project
- BID DUE DATE CHANGED: All bids are due by Tuesday, October 22 at 10:00AM
- If door does not close properly prior to installation, township will be responsible to get door repaired
- Working hours of project are Monday – Friday, 8:00AM – 4:30PM.
- All photos of door handles are uploaded on MITN
- Now included in bid will be swapping out all existing 14 prox card readers at DPW to HID iClass SE R40 readers
- Included in bid is 300 HID iClass Seos 500x cards
- Use iClass SE R40 readers and iClass Seos 500x cards for municipal office site as well

To Be Answered in Second Addendum – Expected to Be Posted by Tuesday, October 15

- Verifying if HID iClass Seos 500x cards will work with our setup at DPW
- Verifying if HID iClass Se R40 readers will work with our setup at DPW
- Verifying if we will have Kantech and ExaqVision connected to work together
- Verifying if Kantech System has a max capacity of cameras