



Manhole Inspection Form

M1-5-3-3-8-5



Manhole Number	M1-5-3-3-8-5	Historic Manhole Number	Greenbriar 5
Year Installed	1992	Structure Type	Sanitary Manhole
Street	Greenbriar	Address	46562
Elevation	591.117	Weather	Overcast
Temperature	20°	Ground Condition	Wet
Status	At Surface Grade	Location	Yard Front
Pavment Condition	N/A	Traffic	No Traffic at Location
Inspector 1	Brs	Inspector 2	Kmd
Cover Type	Ej1040a	Number of Cover Holes	Solid Cover
Catch Basin Cover	N/A	Cover Insert	No
Cover Gasket	No	Cover Grade	Cover is Below Grade
Grade Dist	6	Cover Fit	Good Fit
Cover Condition	Good	Frame Condition	Good
Frame Offset	<null>	Frame Seal Condition	Fair
Frame Seal Inflow	None	Frame Riser	No
Frame Riser Height	<null>	Frame Riser Material	N/A
Manhole Diameter	48	Manhole Depth	8.6
Chimney Depth	<null>	Chimney Construction	None
Chimney Condition	<null>	Chimney Inflow	<null>
Cone Shape	Eccentric	Cone Depth	38
Cone Construction	Precast	Cone Condition	Good
Cone Inflow	Low	Cone Defect Location	Wall/Cone Joint
Wall Construction	Precast	Wall Condition	Good
Wall Inflow	None	Wall Defect Location	<null>
Wall Defect Location 2	<null>	Wall Defect Location 3	<null>
Wall Defect Location 4	<null>	Wall Defect Location 5	<null>
Bench Construction	Poured	Bench Condition	Good
Bench Inflow	None	Channel Construction	Poured
Channel Condition	Good	Channel Inflow	None
Channel Hydraulics	Good	Channel Exposure	Yes



Manhole Inspection Form

M1-5-3-3-8-5



Step Construction	Plastic	Step Condition	Good
Surcharge Evidence	<null>		
Pipe 1 Flow	Inward Flow	Pipe 1 Diameter	8
Pipe 1 Direction	N	Pipe 1 Depth	8.55
Pipe 1 Material	Truss	Pipe 1 Seal Condition	Good
Pipe 1 Drop	<null>	Pipe 1 Comments	<null>
Pipe 2 Flow	Outward Flow	Pipe 2 Diameter	8
Pipe 2 Direction	SW	Pipe 2 Depth	8.6
Pipe 2 Material	Truss	Pipe 2 Seal Condition	Good
Pipe 2 Drop	<null>	Pipe 2 Comments	<null>
Pipe 3 Flow	<null>	Pipe 3 Diameter	<null>
Pipe 3 Direction	<null>	Pipe 3 Depth	<null>
Pipe 3 Material	<null>	Pipe 3 Seal Condition	<null>
Pipe 3 Drop	<null>	Pipe 3 Comments	<null>
Pipe 4 Flow	<null>	Pipe 4 Diameter	<null>
Pipe 4 Direction	<null>	Pipe 4 Depth	<null>
Pipe 4 Material	<null>	Pipe 4 Seal Condition	<null>
Pipe 4 Drop	<null>	Pipe 4 Comments	<null>
Pipe 5 Flow	<null>	Pipe 5 Diameter	<null>
Pipe 5 Direction	<null>	Pipe 5 Depth	<null>
Pipe 5 Material	<null>	Pipe 5 Seal Condition	<null>
Pipe 5 Drop	<null>	Pipe 5 Comments	<null>
Pipe 6 Flow	<null>	Pipe 6 Diameter	<null>
Pipe 6 Direction	<null>	Pipe 6 Depth	<null>
Pipe 6 Material	<null>	Pipe 6 Seal Condition	<null>
Pipe 6 Drop	<null>	Pipe 6 Comments	<null>
Recommendation 1	Raise	Recommendation 2	<null>
Recommendation 3	<null>	Recommendation 4	<null>
Recommendation 5	<null>	Recommendation 6	<null>



Manhole Inspection Form

M1-5-3-3-8-5



Recommendation 7	<null>	Recommendation 8	<null>
Manhole Rating	2 – Failure unlikely in 20 years (Good)	Comments	Buried 6"



Manhole Inspection Form

M1-5-3-3-8-5





Manhole Inspection Form

M1-5-3-3-8-5






Manhole Inspection Form

M1-5-3-3-8-5





Manhole Inspection Form

M1-5-3-3-8-5



Date: 12/14/16

Address: 46562 Greenbriar

R.T. = 8.60'

D = 48"

Map: 52

12.25
-3.65

8.60

4.35
-3.65

70

NORTH

Manhole Number: M1-5-3-3-8-5

Community: Chesterfield


Inspector Initials: KMD / BRS

N 8" Truss
8.55' G

SW 8" Truss
8.60' G

38"

Model: B/4/2016 7:08:25 AM



Manhole Inspection Form

M1-5-3-3-8-5

